

8

7

6

5

4

3

2

1

RETURN

NOTICE - DO NOT ATTEMPT TO START THIS UNIT
INITIAL START-UP MUST BE PERFORMED BY FACTORY AUTHORIZED PERSONNEL. TAMPERING WITH CONTROLS OR AN ATTEMPT TO START THIS UNIT PREMATURELY WILL VOID ALL WARRANTIES, EXPRESSED OR IMPLIED. THE MANUFACTURER IS NOT RESPONSIBLE FOR ITEMS THAT ARE MISSING, BROKEN OR ABUSED.

SUPPLY

FUSES

2.5 AMP CLASS
CC, 600V

FUSES

2.5 AMP CLASS
CC, 600V

FUSES

2.0 AMP CLASS
CC, 600V

FUSES

2.0 AMP CLASS
CC, 600V

FUSES

2.0 AMP CLASS
CC, 600V

FUSES

1.5 AMP CLASS
CC, 600V

GR

EQUIPMENT
EARTH
GROUND

FUSES

REPLACE ELEMENT FUSES
WITH 60 AMP CLASS 1, 600V
FUSES ONLY

FUSES

REPLACE ELEMENT FUSES
WITH 60 AMP CLASS 1, 600V
FUSES ONLY

WARNING

TO PREVENT DANGEROUS SHOCK, MAIN
POWER SOURCE MUST BE
DISCONNECTED BEFORE SERVICING

AVERTISSEMENT

COUPEZ TOUTE ALIMENTATION AVANT DE
TRAVAILLER SUR L'APPAREIL.

USE COPPER WIRE OF THE PROPER
SIZE WITH AN INSULATION RATING OF
194° (90°C) FOR INCOMING
ELECTRICAL SERVICE

POWER SUPPLY
CONNECTION

HIGH
LIMIT

FUSES

REPLACE ELEMENT FUSES
WITH 60 AMP CLASS 1, 600V
FUSES ONLY

POWER SUPPLY
CONNECTION

RESET

FUSES

REPLACE ELEMENT FUSES
WITH 60 AMP CLASS 1, 600V
FUSES ONLY

POWER SUPPLY
CONNECTION

ASME
DATA

WARNING - HIGH VOLTAGE
MAY BE CONNECTED TO MORE
THAN ONE BRANCH CIRCUIT.
BEFORE SERVICING THIS UNIT,
DISCONNECT ALL NECESSARY
CIRCUITS TO INTERRUPT POWER.

CAUTION
USE COPPER WIRE ONLY,
SUITABLE FOR 90°C
ATTENTION
EMPLOYER DE FILS
D'ALIMENTATION SEUL
POUR 90°C

WARNING - HIGH VOLTAGE
MAY BE CONNECTED TO MORE
THAN ONE BRANCH CIRCUIT.
BEFORE SERVICING THIS UNIT,
DISCONNECT ALL NECESSARY
CIRCUITS TO INTERRUPT POWER.

1

.

RELEASE FOR PROTOTYPE

9/16/24

DR

SS

REV

ECN

REVISIONS

DATE

BY

APVD

THESE DRAWINGS AND/OR SPECIFICATIONS ARE THE PROPERTY OF AERCO INTERNATIONAL, INC. THEY ARE ISSUED IN STRICT CONFIDENCE AND SHALL NOT BE REPRODUCED, COPIED, OR USED AS THE BASIS FOR MANUFACTURE OR SALE OF APPARATUS WITHOUT PERMISSION OF THE OWNER.

THIRD ANGLE PROJECTION

ORIGINAL
DWG. SIZE

B

DRAWN BY: D. RULAND

DATE: 9/16/24

CHECKED BY: S. SINGH

DATE: 9/16/24

ALL DIMENSIONS ARE IN INCHES AND ALL TOLERANCES ARE
AS FOLLOWS UNLESS OTHERWISE SPECIFIED
XX ±.015 XXX ± .005 FRACTIONS 1/32± ANGLES ±1°
DIAMETERS ON A COMMON AXIS .005 TOTAL
PERPENDICULARITY/PARALLELISM/FLATNESS .003 TOTAL
ALL DIMENSIONS ARE AFTER FINISH OR PLATING

TITLE

MASTER LABEL SHEET, BMK-E

MAT'L SPEC.:
SEE NOTES

DWG. NO.:
72304

SHEET 1 OF 1

REV

1

100 ORITANI DRIVE | BLAUVELT, NY 10913
aerco.com

1

2

3

4

5

6

7

8

1.

LABEL MUST MEET REQUIREMENTS OF UL MARKING AND LABELING SYSTEM (PGDQ2).

4.

FONT TO BE 'ARIAL'

5.

LABEL TO HAVE PRESSURE SENSITIVE ADHESIVE BACKING.

6.

FINISH TO BE 1 MIL CLEAR POLYESTER LAMINATION.